

Accreditation Certificate

CG Power Systems Ireland

Dublin Road, Cavan, Ireland

Testing Laboratory

Registration number: 269T

is accredited by the Irish National Accreditation Board (INAB) to undertake testing as detailed in the Schedule bearing the Registration Number detailed above, in compliance with the International Standard **ISO/IEC 17025:2005 2nd Edition**


*“General Requirements for the Competence of Testing and Calibration Laboratories”
(This Certificate must be read in conjunction with the Annexed Schedule of Accreditation)*


Date of award of accreditation: **07:09:2010**

Date of last renewal of accreditation: **01:09:2015**

Expiry date of this certificate of accreditation: **01:09:2020**

This Accreditation shall remain in force until further notice subject to continuing compliance with INAB accreditation criteria, ISO/IEC 17025 and any further requirements specified by the Irish National Accreditation Board.

Manager: 
Dr Adrienne Duff

Chairperson: 
Mr Tom O'Neill

Issued on 01 September 2015

Organisations are subject to annual surveillance and are re-assessed every five years. The renewal date on this Certificate confirms the latest date of renewal of accreditation. To confirm the validity of this Certificate, please contact the Irish National Accreditation Board.

The INAB is a signatory of the European co-operation for Accreditation (EA) Testing Multilateral Agreement (MLA) and the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement.

Schedule of Accreditation



(Annex to Accreditation Certificate)

Permanent Laboratory:
Category A

CG POWER SYSTEMS IRELAND

Electrical Testing Laboratory

Initial Registration Date : 7-September-2010
Postal Address: Dublin Road
(Address of other locations as they apply) Cavan
Ireland
Telephone: +353 (49) 4331588
Fax: +353 (49) 4332053
E-mail: sarah.connolly@cgglobal.com
Contact Name: Sarah Connolly
Facilities: Normally not available for Public testing

Schedule of Accreditation



Permanent Laboratory:
Category A

THE IRISH NATIONAL ACCREDITATION BOARD (INAB) is the Irish body for the accreditation of organisations including laboratories.

Laboratory accreditation is available to testing and calibration facilities operated by manufacturing organisations, government departments, educational institutions and commercial testing/calibration services. Indeed, any organisation involved in testing, measurement or calibration in any area of technology can seek accreditation for the work it is undertaking.

Each accredited laboratory has been assessed by skilled specialist assessors and found to meet criteria which are in compliance with ISO/IEC 17025 or ISO/IEC 15189 (medical laboratories). Frequent audits, together with periodic inter-laboratory test programmes, ensure that these standards of operation are maintained.

Testing and Calibration Categories:

- Category A:** Permanent laboratory calibration and testing where the laboratory is erected on a fixed location for a period expected to be greater than three years.
- Category B:** Site calibration and testing that is performed by staff sent out on site by a permanent laboratory that is accredited by the Irish National Accreditation Board.
- Category C:** Site calibration and testing that is performed in a site/mobile laboratory or by staff sent out by such a laboratory, the operation of which is the responsibility of a permanent laboratory accredited by the Irish National Accreditation Board.
- Category D:** Site calibration and testing that is performed on site by individuals and organisations that do not have a permanent calibration/testing laboratory. Testing may be performed using
- (a) portable test equipment
 - (b) a site laboratory
 - (c) a mobile laboratory or
 - (d) equipment from a mobile or site laboratory

Standard Specification or Test Procedure Used:

The standard specification or test procedure that is accredited is the issue that is current on the date of the most recent visit, unless otherwise stated.

Glossary of Terms

Facilities:

- Public calibration/testing service:** Commercial operations which actively seek work from others.
- Conditionally available for public calibration/testing:** Established for another primary purpose but, more commonly than not, is available for outside work.
- Normally not available for public calibration/testing:** Unavailable for public calibration/testing more often than not.

Laboratory users wishing to obtain assurance that calibration or test results are reliable and carried out to the Irish National Accreditation Board criteria should insist on receiving an accredited calibration certificate or test report. Users should contact the laboratory directly to ensure that this scope of accreditation is current. INAB will, on request, verify the status and scope.

Scope of Accreditation



CG Power Systems Ireland Electrical Testing Laboratory

Permanent Laboratory:
Category A

INAB Classification number (P9) Materials/products tested	Type of test/properties measured Range of measurement	Standard specifications Equipment/techniques used
365 Miscellaneous Electrical Tests		
.02 High voltage operating equipment	Separate source voltage withstand test (High Voltage) Range - 200 V to 125 kV Measurement of winding Resistance. Range - 0.1 mOhm to 20 kOhm Measurement of Voltage ratio and check of phase displacement Range Ratio 5 to 500 Measurement of Short circuit impedance and load loss:- Range - 10 W - 45 kW (Load Loss) Range - 10 v - 2150 V (Short circuit Impedance) Measurement of No load loss and current Range - 10 W - 45 kW	IEC 60076-3 (Par:7.3.1.1a and 10) Second Edition 3.0 2013-07 IEC 60076-1 (Par:11.2) Edition 3.0 2011 - 04 IEC 60076-1 (Par:11.3) Edition 3.0 2011 - 04 IEC 60076-1 (Par:11.4) Edition 3.0 2011 - 04 IEC 60076-1 (Par:11.5) Edition 3.0 2011 - 04

Scope of Accreditation



CG Power Systems Ireland Electrical Testing Laboratory

Permanent Laboratory:
Category A

INAB Classification number (P9) Materials/products tested	Type of test/properties measured Range of measurement	Standard specifications Equipment/techniques used
365 Miscellaneous Electrical tests		
.02 High Voltage operating equipment	Induced AC voltage test Range - 100 V - 2000 V	IEC 60076-3 (Par:7.3.1.1b and 11.2) Edition 3.0 2013 - 07
	Lightning Impulse test Range - 10 kV - 275 kV	IEC 60076-3 (Par:13) Edition 3.0 2013 - 07 IEC 60076-4 First edition 2002 - 06
	Determination of sound level Range - 20 dB(A) - 100 dB(A)	IEC 60076-10 First edition 2005 - 10
	Temperature rise test Range - 10 W - 45 kW	IEC 60076-2 Edition 3 2011 - 02
	Partial Discharge Range - 5 pC - 1 nC	IEC 60270 Edition 3 2000 - 12